



western union

Telegram

444A EST OCT 6 72 DEA544 DE
DEG146(1845)(1-032552C279)PD 10/05/72 1840
ICS IPMVEIF MVN
ZCZC 193 F AM PDB TDVE MORRIS ILL 5 335P CDT
PMS BOYCE GREAR DIR DIV OF COMPLIANCE, DLR DONT FONE
REGION 3 US ATOMIC ENERGY COMM 799 ROOSEVELT RD
GLEN ELLYN/ILL 60137

SUBJECT DPR25 DRESDEN NUCLEAR POWER STATION UNIT 3.
THIS WILL CONFIRM A CONVERSATION WITH MR H. DANCE OF YOUR
OFFICE AT 1400 HOURS THIS DATE CONCERNING ECCS 350 PSI
LOW REACTOR PRESSURE SWITCHES BEING OUT OF CALIBRATION SHOWED
THAT TWO OF THE FOUR SWITCHES HAD TRIPPED SETTING GREATER THAN
THE LIMIT IN TABLE 3.2.2. OF TECHNICAL SPECIFICATIONS.
TABLE 3.2.2. STATE THE TRIP SETTING SHOULD BE GREATER THAN
330 PSIG AND LESS THAN 350 PSIG PRESSURE SWITCH 3-263-52A2
TRIP SETTING WAS FOUND TO BE 371 PSIG. PRESSURE SWITCH

SF-1201 (FAS-69)

OCT 10 1972

TELETYPE (OTHER THAN MONEY ORDERS)
IS PHYSICAL DELIVERY requested? (YES-AGENT, NO-ADDRESSER)
ADDRESSER SECTION
No. 32-258-2660
AGENT SECTION
NAME & NAME
Time did 10-6 to 10-6 BY 122
delivered or filed mail
Attempts to deliver (Indicate DA or BY)

33-263-52B2 TRIP SETTING WAS FOUND TO BE 356 PSIG.

PRIOR TO THIS CALIBRATION THE "AS LEFT" SETTING ON THESE SWITCHES WAS 355 PLUS OR MINUS 5 PSIG. OUR LIMIT FOR THESE SWITCHES HAS NOW BEEN CHANGED TO 325 PLUS OR MINUS 10 PSIG. THIS SETTING IS IN THE CENTER OF TECHNICAL SPECIFICATIONS PRESSURE RANGE AND ALLOWS GREATER MARGIN FOR INSTRUMENT DRIFT

WALTER P. WORDEN, SUPT.

DRESDEN NUCLEAR POWER STATION

DPR25 3 1400 ECCS 350 PSI 10-4-72 1600 3.2.2. 3.2.2 330 350
3-263-52A2 371 33-263-52B2 356 355 5 325 10 29 E Wd

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

2 330 350
1972 OCT 13 PM 3 52

RECEIVED

8306230258 721120
PDR ADOCK 05000249
S PDR

SF-1201 (RS-89)