



Telegram

445P EST OCT 24 72 DEB873 DE

7/2 OCT 24 PM 4 54

DEH187(1350)(1-024222C298)PD 10/24/72 1547

ICS IPMVEHE MVN

ZCZC 00051 PD TDVE MORRIS ILL 150 10-24 110P CDT

PMS MR BOYCE GREER DLY 150 DIRECTOR DIV OF COMPLIANCE

REGION 3 US ATOMIC ENERGY COMMISSION 799 ROOSEVELT PD

GLEN ELLYN ILL 60137

SUBJECT DPR-25

DESSEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM A CONVERSATION WITH MR H DANCE OF YOUR OFFICE
AT 1100 HOURS THIS DATE CONCERNING NO. 1 OFF GAS MONITOR BEING
OUT OF CALIBRATION ON 10-20-72 THE INSTRUMENT MECHANICS WHILE
MAKING A MONTHLY SURVALANCE CALIBRATION ON UNIT 3 OFF GAS
MONITOR FOUND THE TRIP SETTING ON ONE MONITOR GREATER THAN
SPECIFIED IN THE TECHNICAL SPECIFICATIONS SECTIONS 3.2.D.A OF THE
TECHNICAL SPECIFICATION STATE THAT THE TRIP SETTING FOR

SF-1201 (R5-69)

MONITOR SHALL BE SET AT A VALUE NOT TO EXCEED THE EQUIVILANT OF
STACK RELEASE LIMIT SPECIFIED IN SPECIFICATION 3.8 THE STACK
RELEASE LIMIT UNDER OPERATING CONDITIONS AT THE TIME WAS 0.7 CI/2ND
THE TRIP SETTING ON NO. 1 OFF GAS MONITOR WAS FOUND TO BE
1.0CI/2ND THESE MONITORS DO NOT HAVE A HISTORY OF PREVIOUS FAILURES
THE STATION WILL REVIEW THE PRESENT TRIP SETTING TO DETERMINE
OF A LOWER LIMIT CAN BE USED

W. P. WORDEN

SUPT DRESSEN NUCLEAR POWER STATION

COL DPR-25 3 1100 1 10-20-72 3 3.2.D.1 3.8 0.7 CI/2ND 1 1.0CI/2ND

8306240081 720925
PDR ADCK 05000249
PDR
S

OCT 27 1972

SF-1201 (R5-69)

REGULATORY OPERATIONS, REGION III

Indicent Notification By: Commonwealth Edison Co. (Dresden 3) 50-249

Transmittal Date: October 27, 1972

Distribution:
RO Chief, RT&OB
RO:HQ (4)
Licensing (4)
DR Central Files

U.S. ATOMIC ENERGY COMM.
DIVISION OF COMPLIANCE

1972 OCT 30 PM 12 19

RECEIVED

50-249
indicent