



Telegram

LD001 TDE MORRIS ILLINOIS SEPTEMBER 25, 1972 10:35AM.

BOYCE GRIER,
DIRECTOR
DIVISION OF COMPLIANCE
REGION 3
U.S. ATOMIC ENERGY COMMISSION
709 ROOSEVELT ROAD
GLEN ELLYN ILLINOIS 60137

SUBJECT DPR-25 DRESDEN NUCLEAR POWER STATION UNIT 3

THIS WILL CONFIRM THE CONVERSATION WITH H. DANCE OF YOUR OFFICE AT 0915 HOURS THIS DATE CONCERNING HIGH FLOW SWITCHES ON THE ISOLATION CONDENSER BEING OUT OF CALIBRATION. ON 9-22 72 A ROUTINE THREE MONTH CALIBRATION WAS PERFORMED ON THE HIGH FLOW ISOLATION SWITCHES. ALL FOUR SWITCHES SET POINTS WERE FOUND GREATER THAN THE LIMIT IN TABLE 3.2.1. OF THE TECHNICAL SPECIFICATIONS. THE HIGH STEAM FLOW SWITCHES, DPIS 3-1350 A&B, WERE FOUND SET AT 426.5 AND 435.5 INCHES OF WATER. THE LIMIT

WU 1201 (R 5-69)

IN TABLE 3.2.1. CORRESPONDS TO 425 INCHES OF WATER. THE HIGH CONDENSATE FLOW SWITCHES, DPIS 3-1349 A&B, WERE FOUND SET AT 33.3 AND 33.5 INCHES OF WATER. THE LIMIT IN TABLE 3.2.1. IS 32 INCHES OF WATER. SWITCHES DPIS 3-1350 A&B WERE RESET TO 416.5 AND 417.5 INCHES OF WATER. SWITCHES DPIS 3-1349 A&B WERE RESET TO 29.9 AND 30.1 INCHES OF WATER. PRESENT PLAN ARE TO CHANGE THE AS LEFT SETTINGS ON THESE SWITCHES TO A LOWER VALUE AT THE NEXT CALIBRATION.

8306240089 720925
PDR ADDCK 05000249
PDR

W. P. WORDEN, SUPERINTENDENT
DRESDEN NUCLEAR POWER STATION

U.S. ATOMIC ENERGY COM.
DIVISION OF COMPLIANCE

1972 OCT 5 AM 11 10

RECEIVED

SEP 23 1972

Copy sent PDR

by Regor

WU 1201 (R 5-69)