

LICENSEE EVENT REPORT

CONTROL BLOCK

1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME

LICENSE NUMBER

LICENSE TYPE

EVENT TYPE

7 8 9 14 15 25 26 30 31 32

A L B R F 1 0 0 - 0 0 0 0 0 - 0 0 4 1 1 1 1 0 3

CATEGORY

REPORT TYPE

REPORT SOURCE

DOCKET NUMBER

EVENT DATE

REPORT DATE

7 8 9 57 58 59 60 61 68 69 74 75 80

0 1 CONT L L 0 5 0 - 0 2 5 9 1 2 2 9 7 6

EVENT DESCRIPTION

7 8 9 80

During surveillance testing, pressure switch PS-3-74B (RHR pump discharge low pressure) exceeded technical specification setpoint. Redundant switches were available and this is not a repetitive problem. Switch was recalibrated and functionally tested satisfactorily. BFRO-50-259/772.

SYSTEM CODE

CAUSE CODE

COMPONENT CODE

PRIME COMPONENT SUPPLIER

COMPONENT MANUFACTURER

VIOLATION

7 8 9 10 11 12 17 43 44 47 48

C F E I N S T R U N B O 8 0 N

CAUSE DESCRIPTION

7 8 9 80

Barton model 288 pressure indicating switch #1 drifted below setpoint. Switch was inspected, recalibrated, and functionally tested for repeatability. Serial # 6644 range 0/500 psid.

FACILITY STATUS

% POWER

OTHER STATUS

METHOD OF DISCOVERY

DISCOVERY DESCRIPTION

7 8 9 10 12 13 44 45 46 80

B 0 9 8 NA B During surveillance testing

FORM OF ACTIVITY RELEASED

CONTENT OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

7 8 9 10 11 44 45 80

Z Z NA NA

PERSONNEL EXPOSURES

NUMBER

TYPE

DESCRIPTION

7 8 9 11 12 13 80

0 0 0 Z NA

PERSONNEL INJURIES

NUMBER

DESCRIPTION

7 8 9 11 12 80

0 0 0 NA

OFFSITE CONSEQUENCES

7 8 9 80

NA

LOSS OR DAMAGE TO FACILITY

TYPE

DESCRIPTION

7 8 9 10 80

Z NA

PUBLICITY

7 8 9 80

NA

ADDITIONAL FACTORS

7 8 9 80

NA

7 8 9 80

NA

8306240190 770120
PDR ADOCK 05000259
S PDR

NAME:

PHONE:



259/77-2

TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401

January 20, 1977

IE FILE COPY

Mr. Norman C. Moseley, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
230 Peachtree Street, NW., Suite 1217
Atlanta, Georgia 30303



Dear Mr. Moseley:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 -
DOCKET NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE
OCCURRENCE REPORT BFRO-50-259/772

The enclosed report is to provide details concerning pressure switch PS-3-74B (RHR pump discharge low pressure) that exceeded technical specification setpoint during surveillance testing. This report is submitted in accordance with Browns Ferry Technical Specifications Section 6. This event occurred on Browns Ferry Nuclear Plant unit 1.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox
Director of Power Production

Enclosure (3)

CC (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

793