


IE FILE COPY

TELECOPY

US Nuclear Regulatory Commission  
230 Peachtree St., NW  
Suite 822  
Atlanta, GA 30303

EFRO-50-259/7617

Beginning at 2245 on 9/21/76, the prescribed rate of reactor coolant change during normal heatup was exceeded when averaged over a 1-hour period.

  
H. L. Green

Power Plant Superintendent  
Crown's Ferry Nuclear Plant

8306240251 760930  
PDR ADOCK 05000259  
S PDR