

TELETYPE COPY

TELETYPE

US Nuclear Regulatory Commission
230 Peachtree St., NW
Suite 818
Atlanta, GA 30303

BFRO-50-259/76 15

At 0010 hours, 9/21/76, with unit 1 at rated pressure in startup mode, HPCI failed scheduled test. At 0105, RMC failed required surveillance test. Reactor shutdown was effected and pressure was reduced to 100 psi by 0215 9/21/76.


H. J. Green

Power Plant Superintendent

Browns Ferry Nuclear Plant

8306240270 760930
PDR ADOCK 05000259
S PDR