

2-020959E015 01/15/76

western union

Memorandum

U.S. MAIL
PERMIT NO. 100
ATLANTA, GA 30303

ICS IPMONGZ CSP

2057298316 MGM TDBN ATHENS AL 100 01-15 1252P EST

IE FILE COPY

259/26-1

260/76-2

U S NUCLEAR REGULATORY COMMISSION
230 PEACHTREE ST NORTHWEST SUITE 818
ATLANTA GA 30303

BFAO-50-259/761T

BFAO-50-260/762T

AT APPROXIMATELY 1700 ON JANUARY 14 1976 D DIESEL GENERATOR FAILED
MONTHLY SURVEILLANCE TEST DUE TO MECHANICAL GOVERNOR PROBLEMS. EACH
UNIT HAS THE FUEL REMOVED FROM THE VESSEL AND STORED IN ITS SPENT FUEL
POOL.

H J GREEN

BROWNS FERRY NUCLEAR PLANT

12:52 EST

MGMATLT. HSB

8306240340 760123
PDR ADOCK 05000259
S PDR