



300 Madison Avenue  
Toledo, OH 43652-0001  
419-243-2300

John P. Stetz  
Vice President - Nuclear  
Davis-Besse

Docket Number 50-346

License Number NPF-3

Serial Number 2288

June 7, 1995

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Subject: License Amendment Application to Revise Technical Specifications and Associated Bases for Refueling Operations - Containment Penetrations

Ladies and Gentlemen:

Enclosed is an application for an amendment to the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1 Operating License NPF-3, Appendix A, Technical Specifications, to reflect the changes attached. The proposed changes involve Technical Specification (TS) 3/4.9.4, Refueling Operations - Containment Penetrations, and associated Bases 3/4.9.4, Containment Penetrations.

The proposed change would revise TS Limiting Condition for Operation (LCO) 3.9.4.b to allow both doors of the containment personnel airlock to be open during core alterations or movement of irradiated fuel within the containment, provided that certain specified conditions are met. The proposed change would also clarify TS LCO 3.9.4.c, and would make administrative changes to Action statement 3.9.4.a and Surveillance Requirement (SR) 4.9.4. Associated changes to the Bases are also proposed.

1506130059 950607  
PDR ADDCK 05000346  
P PDR

Operating Companies  
Cleveland Electric Illuminating  
Toledo Edison


ADD

Docket Number 50-346  
License Number NPF-3  
Serial Number 2288  
Page 2

In order to support planning for the Tenth Refueling Outage (10RFO), which is currently scheduled to commence on April 8, 1996, Toledo Edison requests that this amendment be issued by the NRC by December 5, 1995.

Should you have any questions or require additional information, please contact Mr. William T. O'Connor, Manager -- Regulatory Affairs, at (419) 249-2366.

Very truly yours,



MKL/laj

cc: L. L. Gundrum, DB-1 NRC/NRR Project Manager  
J. B. Martin, Regional Administrator, NRC Region III  
S. Stasek, DB-1 NRC Senior Resident Inspector  
J. R. Williams, Chief of Staff, Ohio Emergency Management  
Agency, State of Ohio (NRC Liaison)  
Utility Radiological Safety Board