

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

PLEASE PRINT ALL REQUIRED INFORMATION

LICENSEE NAME

LICENSE NUMBER

LICENSE TYPE

EVENT TYPE

01 A L B R F 3

0 0 - 0 0 0 0 0 - 0 0

4 1 1 1 1

0 3

01 CONT CATEGORY L L

0 5 0 - 0 2 9 6

1 0 2 0 7 6

REPORT DATE

EVENT DESCRIPTION

02 A false alarm was received from a smoke detector in spreading room B due to increased
 03 detector sensitivity. (BFRO-50-296/7616)
 04
 05
 06

SYSTEM CAUSE COMPONENT PRIME COMPONENT VIOLATION
 CODE CODE CODE COMPONENT SUPPLIER MANUFACTURER
 07 A B E I N S T R U L K 1 2 0 N

CAUSE DESCRIPTION

08 The smoke detector needed cleaning.
 09
 10

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 11 B 0 0 5 NA A Alarm received in control room
 FORM OF ACTIVITY RELEASED CONTENT OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 12 2 2 NA NA

PERSONNEL EXPOSURES

13 0 0 0 2 NA

PERSONNEL INJURIES

14 0 0 0 NA

OFFSITE CONSEQUENCES

15 NA

LOSS OR DAMAGE TO FACILITY

16 2 NA S 8306270033 761116 PDR ADOCK 05000296 PDR

PUBLICITY

17 NA

ADDITIONAL FACTORS

18 The smoke detector was cleaned and returned to normal.
 19

NAME:

PHONE:

CPD 881-007



TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

November 16, 1976

Mr. Norman C. Moseley, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
230 Peachtree Street, NW., 8th Floor
Atlanta, Georgia 30303

IE FILE COPY



Dear Mr. Moseley:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 -
DOCKET NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE
OCCURRENCE REPORT BFRO-50-296/7616

The enclosed report is to provide details concerning the false alarm that was received from a smoke detector in spreading room B due to increased detector sensitivity. This report is submitted in accordance with Browns Ferry Technical Specifications Section 6. This event occurred on Browns Ferry Nuclear Plant unit 3.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox
Director of Power Production

Enclosure (3)
CC (Enclosure):
Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director (40) /
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

11854

COPY SENT REGION II