

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME			LICENSE NUMBER										LICENSE TYPE					EVENT TYPE									
01	A	L	B	R	F	3	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	3			
7	8	9				14	15											25	26						30	31	32

  

CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER										EVENT DATE					REPORT DATE										
01	CONT			L	L	0	5	0	-	0	2	9	6	0	9	2	3	7	6												
7	8	57	58	59	60	61											68	69						74	75						80

EVENT DESCRIPTION

02	During the performance of a surveillance test, the RHR pump 3C failed to start on																								80
03	normal power. The other three RHR pumps were operable. RHR pump 3C would have																								80
04	operated on emergency power. (BFR0-50-296/769).																								80
05																									80
06																									80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE								PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION		
07	C	F	F	X	X	X	X	X	X	X	Z	Z	9	9	9	9	N			
7	8	9	10									17	43					44	47	48

CAUSE DESCRIPTION

08	A cable in the RHR logic was found open.																								80
09																									80
10																									80

FACILITY STATUS		% POWER		OTHER STATUS								METHOD OF DISCOVERY		DISCOVERY DESCRIPTION													
11	B	0	2	5	NA								B	NA													
7	8	9	10	12	13									44	45	46											80

  

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY								LOCATION OF RELEASE													
12	Z	Z	NA								NA														
7	8	9	10	11									44	45											80

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION																						
13	0	0	0	Z	NA																					
7	8	9	11	12	13																					80

PERSONNEL INJURIES

NUMBER		DESCRIPTION																									
14	0	0	0	NA																							
7	8	9	11	12																							80

OFFSITE CONSEQUENCES

15	NA																								80
----	----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION																						
16	Z	NA																						80

PUBLICITY

17	<div style="display: flex; justify-content: space-between;"> <span>8306270056 761007</span> <span>PDR ADOCK 05000296</span> </div> <div style="display: flex; justify-content: space-between;"> <span>S</span> <span>PDR</span> </div>																								80
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

ADDITIONAL FACTORS

18	The open cable was replaced and the surveillance test performed satisfactorily.																								80
19																									80

NAME: \_\_\_\_\_ PHONE: \_\_\_\_\_



76-9

— TENNESSEE VALLEY AUTHORITY  
CHATTANOOGA, TENNESSEE 37401

October 7, 1976



Mr. Norman C. Moseley, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
230 Peachtree Street, NW., 8th Floor  
Atlanta, Georgia 30303

Dear Mr. Moseley:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 -  
DOCKET NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE  
OCCURRENCE REPORT BFRO-50-296/769

The enclosed report is to provide details concerning the RHR pump 3C that failed to start on normal power during the performance of a surveillance test. This report is submitted in accordance with Browns Ferry Technical Specifications Section 6. This event occurred on Browns Ferry Nuclear Plant unit 3.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox  
Director of Power Production

Enclosure (3)

CC (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

10907