

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME				LICENSE NUMBER										LICENSE TYPE					EVENT TYPE					
01	A	L	B	F	1	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	3	
7	8	9			14	15										25	26					30	31	32

CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER						EVENT DATE					REPORT DATE								
01	CONT	L	L	0	5	0	-	0	2	5	9	0	9	2	3	7	6						
7	8	57	58	59	60	61					68	69				74	75					80	

EVENT DESCRIPTION

02	The loop II core spray sparger/vessel DP (PDIS-75-56) was found valved out. The	80
03	switch was valved into service and the alarm was cleared. (BFR0-50-259/7620)	80
04		80
05		80
06		80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION		
07	I	D	A	I	N	S	T	R	U	N	B	O	S	O	N
7	8	9	10	11	12				17	43	44			47	48

CAUSE DESCRIPTION

08	The instrument was apparently left valved out following removal of temporary tygon	80
09	tubing connections used for monitoring the R.V. water level during a recent outage.	80
10		80

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
11	B	0	0	3	NA	B		Investigation of Alarms			
7	8	9	10	12	13	44	45	46			80

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
12	Z	Z		NA		NA			
7	8	9	10	11		44	45		80

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
13	0	0	0
7	8	9	11

PERSONNEL INJURIES

NUMBER		DESCRIPTION
14	0	0
7	8	9

OFFSITE CONSEQUENCES

15	NA	80
----	----	----

LOSS OR DAMAGE TO FACILITY

TYPE	DESCRIPTION
16	Z
7	8

PUBLICITY

17	NA	80
----	----	----

ADDITIONAL FACTORS

18	A Section Instruction Letter will be issued to require the return to normal service	80
19	all instruments upon completion of any work not covered by existing plant instructions.	80
20	Conformance to this policy has been emphasized with all instrument mechanics.	80

8306270084 761022
 PDR ADOCK 05000259
 S PDR



TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

October 22, 1976

FILE COPY



Mr. Norman C. Moseley, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
230 Peachtree Street, NW., 8th Floor
Atlanta, Georgia 30303

Dear Mr. Moseley:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 -
DOCKET NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE
OCCURRENCE REPORT BFR0-50-259/7620

The enclosed report is to provide details concerning the loop II core
spray sparger/vessel DP (PdIS-75-56) which was found valved out. This
report is submitted in accordance with Browns Ferry Technical Specifi-
cations Section 6. This event occurred on Browns Ferry Nuclear Plant
unit 1.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox
Director of Power Production

Enclosure (3)

CC (Enclosure):

Director (3)

Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director (40)

Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

11200