



Commonwealth Edison
Quad-Cities Nuclear Power Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-75-136

Telecopy: Region III, Attention: Mr. C. Feierabend

March 14, 1975

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.0.A.2, 4.7.A.2.1.2.B, 6.6.B.1.a

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

With Unit 2 in the cold shutdown condition for the current refueling outage, the main steam isolation valve 2-203-2A was determined to have leakage in excess of the Technical Specification leak rate limitation of 11.5 SCFH.

In accordance with our previous reporting agreement of April 4, 1974, this notification also fulfills the Ten Day Reporting Requirement of Technical Specification 6.6.B.1.B. Details of repairs necessary to correct these deficiencies will be reported at a later date when the work is complete.

This occurrence was discussed by telephone with Mr. Feierabend of your office on March 14, 1975. Further information will be provided by Abnormal Occurrence Report AO-50-265/75-9.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/lk

cc: Directorate of Licensing
J. S. Abel

8306270135 750320
PDR ADOCK 05000265
S PDR

Rec'd 4.42 3/14