



Telegram

VEA623(2307)(1-0194150239)PD 02/08/77 1531

1977 FEB -8 PM 10: 39

TLX CONSPower JKN

ZCZC 001 DLY JACKSON MICH 2/8/77

PMS KEN BAKER

NUCLEAR REGULATORY COMMISSION (FORMERLY AEC)

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

AC 312 BOOK NO 40/LB3 OPR. NO. 119

TELEPHONE NBR. 858 2660

TELEPHONED TO SDK BY ct

DATE DLD. 2/9 TIME 8:57A

SUBJECT - ER-77-014

ATTEMPTS TO DELIVER:

mail

CONFIRMING CALL TO KEN BAKER ON 2/8 AT 1330:

ON 1/7 AT 1400 AND 1550 THE INTAKE/DISCHARGE WATER TEMPERATURE
DELTA T LIMIT WAS EXCEEDED AS FOLLOWS:

FEB 11 1977

SF-1201 (RS-69)

1400 - 1412 AVE DELTA T EQUAL 5.7 MAX 5.7

1550 - 1600 AVE DELTA T EQUAL 6.2 MAX 9.9

J G LEWIS

PALISADES NUCLEAR PLANT

CONSUMERS POWER COMPANY

CBW

NNNN

8306280243 770222
PDR ADDOCK 05000255
S PDR

SF-1201 (RS-69)