



Telegram

VED180(1346)(1-016189C032)PD 02/01/77 1344

TLX CONSPower JKM

ZCZC 002 DLY JACKSON MICH 2/1/77

PMS K R BAKER

NUCLEAR REGULATORY COMMISSION (FORMERLY ARD)

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

3/4 BOOK NO.

OPR. NO.

TELEPHONE NBR.

TELEPHONED TO

BY

DATE DLD.

TIME

ATTEMPTS TO DELIVER:

SUBJECT: EVENT REPORT 77-009

CONFIRMING CALL TO K R BAKER ON 1/30/77 AT 0950 AND 1830 THE INTAKE
DISCHARGE WATER TEMP DELTA T LIMIT WAS EXCEEDED AS FOLLOWS:

0950-1340 AVE DELTA T - 5.7 AVE BTU/HR -- 177.9

FEB 4 1977

SF-1201 (RS-69)

1830-0030 AVE DELTA T - 7.2 AVE BTU/HR -- 223.3

THESE EXCEEDINGS WERE IN VIOLATION OF OUR TECH SPECS SECTION
3.9 AND 4.1.

J G LEWIS

PALISADES PLANT

CONSUMERS POWER COMPANY

CBW

NNNN

8306280277 770209
PDR ADOCK 05000255
S PDR

SF-1201 (RS-69)