

TELECOPY

US Nuclear Regulatory Commission  
230 Peachtree Street, NW  
Suite 810  
Atlanta, GA 30303

BTED-50-295/762T

On July 28, 1976, during the review of surveillance testing,  
the control rod accumulators were found discharged without the  
control rod drive being electrically disarmed.

*H. J. Green*

H. J. Green

Browns Ferry Nuclear Plant

*Telecopied 7/28/76.*  
*438/2*

8306280403 760806  
PDR ADOCK C5000296  
S PDR