

LISCENSEE EVENT REPORT

CONTROL BLOCK:

[PLEASE PRINT ALL REQUIRED INFORMATION]

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---------------|---|---|---|---|---|----|----|---|---|---|---|---|---|----------------|---|---|---|----|----|---|---|---|----|--------------|----|--|--|--|------------|--|
| LICENSEE NAME | | | | | | | | | | | | | | LICENSE NUMBER | | | | | | | | | | LICENSE TYPE | | | | | EVENT TYPE | |
| 01 | A | L | B | R | F | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 0 | 3 | | | | | | |
| 7 | 8 | 9 | | | | 14 | 15 | | | | | | | | | | | 25 | 26 | | | | 30 | 31 | 32 | | | | | |

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|----------|------|-------------|---------------|---------------|----|----|---|---|---|---|------------|---|---|---|-------------|---|---|--|----|--|--|--|----|--|--|--|----|--|--|--|
| CATEGORY | | REPORT TYPE | REPORT SOURCE | DOCKET NUMBER | | | | | | | EVENT DATE | | | | REPORT DATE | | | | | | | | | | | | | | | |
| 01 | CONT | L | L | 0 | 5 | 0 | - | 0 | 2 | 6 | 0 | 0 | 9 | 0 | 4 | 7 | 6 | | | | | | | | | | | | | |
| 7 | 8 | 57 | 58 | 59 | 60 | 61 | | | | | 68 | | | | 69 | | | | 74 | | | | 75 | | | | 80 | | | |

| EVENT DESCRIPTION | DATE | TIME | LOCATION | STATUS |
|-------------------|------|------|----------|--------|
| ... | ... | ... | ... | ... |

| | | |
|----|---|----|
| 02 | Two alarms were received from a smoke detector in the control room due to increased | 80 |
| 03 | detector sensitivity. The detector was cleaned after the first alarm and then | 80 |
| 04 | replaced after the second alarm. (BFRO-50-260/7612) | 80 |
| 05 | | 80 |
| 06 | | 80 |

PRIME

SYSTEM CODE CAUSE CODE COMPONENT CODE COMPONENT SUPPLIER COMPONENT MANUFACTURER VIOLATION

07 AB E INSTRU L K120 N

7 8 9 10 11 12 17 43 44 47 48

CAUSE DESCRIPTION

| | | |
|-------|------------------|----|
| 00 | Detector failed. | 80 |
| 7 8 9 | | |
| 09 | | 80 |
| 7 8 9 | | |
| 10 | | 80 |
| 7 8 9 | | |

| FACILITY STATUS | | % POWER | | | OTHER STATUS | | METHOD OF DISCOVERY | | DISCOVERY DESCRIPTION | |
|-----------------|---|---------|----|----|--------------|----|---------------------|--------------------------------|-----------------------|----|
| 11 | G | 0 | 0 | 0 | NA | | A | Alarm received in control room | | |
| 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 |

| FORM OF ACTIVITY RELEASED | | CONTENT OF RELEASE | AMOUNT OF ACTIVITY | LOCATION OF RELEASE |
|---------------------------|---|--------------------|--------------------|---------------------|
| 1 | 2 | 3 | NA | NA |
| 7 | 8 | 10 | 11 | 44 |
| | | | | 45 |
| | | | | 80 |

PERSONNEL EXPOSURES

| NUMBER | | | | TYPE | DESCRIPTION |
|--------|---|---|---|------|-------------|
| 1 | 5 | 0 | 0 | d | 2 NA |

PERSONNEL INJURIES

| NUMBER | | | | DESCRIPTION |
|--------|---|---|---|-------------|
| 1 | 4 | 0 | 0 | NA |

OFFSITE CONSEQUENCES

7 8 9 NA BC

LOSS OR DAMAGE TO FACILITY

| *VFC | | DESCRIPTION | |
|------|---|-------------|----|
| 1 | 2 | NA | |
| 7 | 8 | | 80 |

PUBLICITY

NA

ADDITIONAL FACTORS

| | | | | | |
|---|---|---|----|-----|-----|
| 7 | 8 | 9 | NA | PDR | PDR |
| | | | | S | |

NAME _____

PHONE

CPQ 1567



TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401

260/76-12

September 29, 1976



Mr. Norman C. Moseley, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
230 Peachtree Street, NW., 8th Floor
Atlanta, Georgia 30303

Dear Mr. Moseley:

TENNESSEE VALLEY AUTHORITY - BROWNS PERRY NUCLEAR PLANT UNIT 2 -
DOCKET NO. 50-260 - FACILITY OPERATING LICENSE DPR-52 - REIMPORTABLE
OCCURRENCE REPORT DPRO 50-260/7612

The enclosed report is to provide details concerning two alarms that were received from a smoke detector in the control room due to increased detector sensitivity. This report is submitted in accordance with Browns Perry Technical Specifications Section 6. This event occurred on Browns Perry Nuclear Plant unit 2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox
Director of Power Production

Enclosure (3)

CC (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

10075

COPY SENT REGION ~~II~~