



Consumers
Power
Company

IE FILE COPY

COPY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

February 8, 1977

Mr James G Keppler
Office of Inspection & Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137



DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - WITHDRAWAL OF ER-77-06 -
CONTROL ROD MISALIGNED

By letter dated February 2, 1977, Event Report 77-06 for the Palisades Plant was transmitted to the Office of Inspection & Enforcement, Region III. After reviewing the event, the plant staff determined that this event was not reportable and obtained the concurrence of the IE staff.

The reactor was subcritical at the time of the control rod No 21 misalignment and the event is, therefore, not reportable per the requirements of Technical Specifications, Section 3.10.4.a. LER-77-06 is, therefore, withdrawn.

David P Hoffman (Signed)

David P Hoffman
Assistant Nuclear Licensing Administrator

8306280571 770208
PDR ADOCK 05000255
S PDR

1378



**Consumers
Power
Company**

FILE COPY

COPY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

February 2, 1977



Mr James G Keppler
Office of Inspection & Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255, LICENSE DPR-20 -
PALISADES PLANT, ER-77-06, ER-77-08 -
CONTROL ROD MISALIGNED

Attached are reportable occurrences which relate to the Palisades Plant. These occurrences involve the misalignment of a control rod. Per telecon with Mr Ken Baker (NRC, Region III), an extension beyond the 14-day submittal was granted.

David P Hoffman (Signed)

David P Hoffman
Assistant Nuclear Licensing Administrator

1336