



Consumers
Power
Company

IE FILE COPY

COPY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

January 31, 1977

Mr James G Keppler
Office of Inspection and Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137



DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - ER-77-04 -
DISCHARGE ABOVE 5°F LIMIT

Attached is a reportable occurrence which related to the Palisades Plant.
This occurrence involves the discharge of cooling water above the 5°F limit
and occurred during plant and/or cooling tower start-up or shutdown.

David A Bixel (Signed)

David A Bixel
Assistant Nuclear Licensing Administrator

8306280587 770131
PDR ADOCK 05000255
S PDR

921