


TE FILE COPY



Telegram

AAB192(1625)(2-044265E251)PD 09/07/76 1625

ICS IPMBNGZ CSP

DUPLICATE OF TELEPHONE TELEGRAM

2057298316 NL TDBN DECATUR AL 100 09-07 0425P EST

PMS U.S. ATOMIC ENERGY COMMISSION REGION II DIRECTORATE OF REGULATORY OPERATIONS

230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

BFRO-50-260/7610 DURING SCRAM TIME TESTING WITH UNIT 2 REACTOR AT
HOT STANDBY AN OUT OF SEQUENCE CONTROL ROD WAS WITHDRAWN ON
SEPTEMBER 6 1976

H J GREEN POWER PLANT SUPT BROWNS FERRY NUCLEAR PLANT

NNNN

206 10 10 10 10 10

526-4503

SD
8/00/8557 - MAIL

SF-1201 (RS-69)

8306280626 760917
PDR ADOCK 05000260
S PDR