

TELETYPE

US Nuclear Regulatory Commission
230 Peachtree Street, NE
Suite 818
Atlanta, GA 30303 >

BTRO-50-260/76BT

At 1255 July 9, 1976, unit 2 scrammed due to the loss of neutron monitoring battery 2A. Power was restored at 1530 July 9, 1976. The reactor was in a shut down condition with the head off.

H. J. Green

Browns Ferry Nuclear Plant

50-260