

Telegram

western union

m

western union

Telegram

1123A EST MAR 28 72 DFA124 KA093

K VEA226 (DE CCD449 (JH 087CC421449 ZCZC 23 NL PD MORRIS ILL

27

BOYCE GRIER DIR AEC COMPLIANCE REGENT 111

1972 MAR 28 AM 10 56

US ATOMIC ENRGY COMM⁷⁹⁹/ROOSEVELT RD GLENELLYN ILL (RTE MAYWOOD
ILL RTE DIR

BT

SUBJECT D.PR25 DRESDEN NUCLEAR POWER STATION UNIT THREE. THIS
WILL CONFIRM CONVERSATION AT 1600 HOURS THIS DATE WITH MR FIORELLA
RE EXCEEDING SECONDARY CONTAINMENT REQUIREMENTS SPECIFIED IN
SECTION 3.7.CM1 FOR A PERIOD OF NO GREATER THAN 2 HOURS. THE
CONDITION RESULTED WHEN BOTH RAILROAD DOORS ON THED-2-3 AIR
LOCK WERE LEFT OPEN SOMETIME AFTER 1100 HOURS ON 3-27-72. THE
CAUSE OF THIS VIOLATION OF ESTABLISHED PROCEDURES HAS NOT AS
YET BEEN DETERMINED. THE VIOLATION WAS DISCOVERED AT 1300 HOURS

AND SECONDARY CONTAINMENT INTEGRITY RESTORED AT 1310 HOURS.
UNIT 111 WAS OPERATING DURING THIS PERIOD WHILE UNIT 11 WAS
IN THE REFUEL MODE. TO PREVENT A SIMILAR INCIDENT IN THE FUTURE
BOTH THE INNER AND OUTER DOORS HAVE BEEN AND WILL REMAIN LOCKED
EXCEPT DURING AUTHORIZED USE. THIS OCCURRENCE IS REPORTED UNDER
SECTION 6.6.A.1 OF THE TECHNICAL SPECIFICATION

W P WORDEN SUPT DRESDEN NUCLEAR POWER STATION RR 1 MORRIS
ILL.

8306280659 720405
PDR ADDCK 05000237
S PDR

50-249

Recd. 3/28/72

2 0570

Copy sent PDR