

OPERATING DATA REPORT

DOCKET NO. 50-336
 DATE 04/02/91
 COMPLETED BY G. Neron
 TELEPHONE (203) 447-1791
 EXT. 4417

OPERATING STATUS

1. Unit Name: Millstone Unit 2
2. Reporting Period: January 1991
3. Licensed Thermal Power (MWt): 2700
4. Nameplate Rating (Gross MWe): 909
5. Design Electrical Rating (Net MWe): 870
6. Maximum Dependable Capacity (Gross MWe): 893.88
7. Maximum Dependable Capacity (Net MWe): 862.88
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
N/A

Notes: Items 21 and 22 cumulative are weighted averages. Unit operated at 2560 MWTH prior to its uprating to the current 2700 MWTH power level.

9. Power Level To Which Restricted, If any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-To-Date	Cumulative
11. Hours In Reporting Period	744.0	744.0	132384.0
12. Number Of Hours Reactor Was Critical	553.0	553.0	97465.6
13. Reactor Reserve Shutdown Hours	0.0	0.0	2205.5
14. Hours Generator On-Line	511.1	511.1	92854.9
15. Unit Reserve Shutdown Hours	0.0	0.0	468.2
16. Gross Thermal Energy Generated (MWH)	1323684.0	1323684.0	256379748.4
17. Gross Electrical Energy Generated (MWH)	438940.5	438940.5	77878640.0
18. Net Electrical Energy Generated (MWH)	420145.5	420145.5	74721195.0
19. Unit Service Factor	68.7	68.7	70.1
20. Unit Availability Factor	68.7	68.7	70.5
21. Unit Capacity Factor (Using MDC Net)	55.4	65.4	* 66.3
22. Unit Capacity Factor (Using DER Net)	64.9	64.9	* 65.0
23. Unit Forced Outage Rate	31.3	31.3	13.3
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>N/A</u>			

25. If Unit Shutdown At End Of Report Period, Estimated Date of Startup: N/A
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

* REVISED DATA VALUES DUE TO TYPO