

260/76-5


TE FILE COPY

Teletype

US Nuclear Regulatory Commission
190 Peachtree St., NW
Suite 818
Atlanta, GA 30303

BRAC-50-260/765T

On June 19, 1976, water supply valves (85-612 and 85-615) to hydraulic control unit 30-31 were found closed. They were immediately opened as required by technical specifications.


H. J. Green

Power Plant Superintendent
Browns Ferry Nuclear Plant

8306290052 760702
PDR ADDCK 05000260
S PDR