



Telegram

VED093(1056)(1-007843M342)PD 12/08/77 1054

1977 DEC -8 AM 9:58

TLX CPCO PARN JKN

50-255

ZCZC 1 JACKSON MI 12-8-77

PMS NUCLEAR REGULATORY COMMISSION

/FORMERLY US ATOMIC ENERGY COM/

MR D R HUNTER

799 ROOSEVELT RD

GLEN ELLYN IL 60137

ATT- D R HUNTER

TELEPHONE NO.

312-858-2660

TELETYPE NO.

FDK

BY 115

DATE DLD

12-08

TIME

123P

ATTEMPTS TO DELIVER.

Mail

THIS CONFIRMS EVENT REPORT 77-056 AT PALISADES PLANT, PREVIOUSLY
REPORTED BY TELEPHONE TO D R HUNTER ON 12/7/77.

DEC 12 1977

ON 11/29/77, DURING A GASEOUS WASTE RELEASE, THE MAIN EXHAUST FAN
STOPPED CAUSING THE LCO OF T.S. 3.9.15 A TO BE EXCEEDED. THE RE-
LEASE WAS TERMINATED. NO WASTE GAS MONITOR ALARMS WERE RECEIVED NOR

8F-1201 (RS-66)

WERE ANY DISCHARGE LIMITS EXCEEDED.

J G LEWIS

PALISADES PLANT

CONSUMERS POWER COMPANY

JACKSON MI

CC- R B DE WITT

D A BIXEL

NNNN

8306290136 771209
PDR ADOCK 05000255
PDR

DEC 12 1977

8F-1201 (RS-66)



Telegram

VED093(1056)(1-007843M342)PD 12/08/77 1054

1977 DEC -8 AM 9:58

50-255

TLX CPCO PARN JKN

ZCZC 1 JACKSON MI 12-8-77

PMS NUCLEAR REGULATORY COMMISSION

/FORMERLY US ATOMIC ENERGY COM/

MR D R HUNTER

799 ROOSEVELT RD

GLEN ELLYN IL 60137

ATT- D R HUNTER

TELEPHONE NO. 312-858-2660
TELETYPE NO. FDK BY 115
TO OLD 12-08 TIME 123P
ATTEMPTS TO DELIVER. Mail

THIS CONFIRMS EVENT REPORT 77-056 AT PALISADES PLANT, PREVIOUSLY
REPORTED BY TELEPHONE TO D R HUNTER ON 12/7/77.

DEC 12 1977

ON 11/29/77, DURING A GASEOUS WASTE RELEASE, THE MAIN EXHAUST FAN
STOPPED CAUSING THE LCO OF T.S. 3.9.15 A TO BE EXCEEDED. THE RE-
LEASE WAS TERMINATED. NO WASTE GAS MONITOR ALARMS WERE RECEIVED NOR

SF-1201 (RS-69)

WERE ANY DISCHARGE LIMITS EXCEEDED.

J G LEWIS

PALISADES PLANT

CONSUMERS POWER COMPANY

JACKSON MI

CC- R B DE WITT

D A BIXEL

NNNN

DEC 12 1977

SF-1201 (RS-69)