

MGMCGBT HSA
MAILGRAM SERVICE CENTER
MIDDLETOWN, VA. 22645

1-029690N332 11/28/77 TLX CPCO PAHN JKN
1 JACKSON MI NOV 28, 1977

ZIP

 western union Mailgram®



50-255

IE FILE COPY

NUCLEAR REGULATORY COMMISSION
/FORMERLY US ATOMIC ENERGY COM/
MR D R HUNTER
799 ROOSEVELT RD
GLEN ELLYN IL 60137

ATT- D R HUNTER

THIS CONFIRMS EVENT REPORT 77-055 AT PALISADES PLANT, PREVIOUSLY REPORTED BY TELEPHONE TO D R HUNTER ON 11-25-77. AT 0824 ON 11-25-77, LOSS OF OFFSITE POWER OCCURRED, RESULTING IN A LOSS OF MAIN CONDENSER COOLING WATER. THE PLANT WAS IMMEDIATELY TRIPPED MANUALLY. BOTH DIESELS IMMEDIATELY STARTED AND SUPPLIED POWER DURING THE 2.3 HOURS THAT OFFSITE POWER WAS NOT AVAILABLE. OFFSITE POWER AND STARTUP POWER WERE SIMULTANEOUSLY LOST, CAUSING T.S. 3.7.1 TO BE VIOLATED. THE PLANT WAS STABILIZED IN THE HOT CONDITION AND WAS BORATED, RESULTING IN A VIOLATION OF T.S. 3.1.1.A. DURING THE EVENT, A 1/2" LEAK DEVELOPED IN THE LETDOWN LINE. LEAKAGE EXCEEDED THE LIMITS OF T.S. 3.1.5. THE LEAK WAS PROMPTLY ISOLATED AND SUBSEQUENTLY REPAIRED.

J G LEWIS/G H PETITJEAN
CONSUMERS POWER COMPANY
PALISADES PLANT

16:27 EST

MGMCGBT HSA

NOV 29 1977

8306290147 771209
PDR ADOCK 05000255
P PDR

TO REPLY BY MAILGRAM, PHONE WESTERN UNION ANY TIME, DAY OR NIGHT:

FOR YOUR LOCAL NUMBER, SEE THE WHITE PAGES

OF YOUR TELEPHONE DIRECTORY

OR

DIAL (TOLL FREE) 800-267-2241

(EXCEPT IN NEW JERSEY 800-632-2271)

OR DIAL WESTERN UNION'S INFOMASTER SYSTEM DIRECTLY:

FROM TELEX 6161

FROM TWX 910 420 1212



Telegram

VED191(1624)(1-030915M332)PD 11/23/77 1631

50-255
1977 NOV 28 PM 3:33

TLX CPCO PARN JKN

ZCZC 1 JACKSON MI NOV 28, 1977

PMS NUCLEAR REGULATORY COMMISSION

/FORMERLY US ATOMIC ENERGY COM/

MR D R HUNTER

799 ROOSEVELT RD

GLEN ELLYN IL 60137

ATT- D R HUNTER

4013
TELEPHONE NBR. 312 858-2660
TELEPHONED TO SC K BY TH
DATE DLD 11/28 TIME 440p
ATTEMPTS TO DELIVER.

mail

DEC 1 1977

THIS CONFIRMS EVENT REPORT 77-055 AT PALISADES PLANT, PREVIOUSLY REPORTED BY TELEPHONE TO D R HUNTER ON 11-25-77. AT 0824 ON 11-25-77, LOSS OF OFFSITE POWER OCCURRED, RESULTING IN A LOSS OF MAIN CONDENSER COOLING WATER. THE PLANT WAS IMMEDIATELY TRIPPED MANUALLY. BOTH DIESELS IMMEDIATELY STARTED AND SUPPLIED POWER DURING THE 2.3 HOURS THAT OFFSITE POWER WAS NOT AVAILABLE. OFFSITE POWER AND STARTUP POWER

BF-1201 (RS-69)

WERE SIMULTANEOUSLY LOST, CAUSING T.S. 3.7.1 TO BE VIOLATED. THE PLANT WAS STABILIZED IN THE HOT CONDITION AND WAS BORATED, RESULTING IN A VIOLATION OF T.S. 3.1.1.A. DURING THE EVENT, A 1/2" LEAK DEVELOPED IN THE LETDOWN LINE. LEAKAGE EXCEEDED THE LIMITS OF T.S. 3.1.5. THE LEAK WAS PROMPTLY ISOLATED AND SUBSEQUENTLY REPAIRED.

J G LEWIS/G H PETITJEAN
CONSUMERS POWER COMPANY
PALISADES PLANT

NNNN

DEC 1 1977

BF-1201 (RS-69)



Telegram

VED191(1624)(1-030915M332)PD 11/23/77 1631

50-255
1977 NOV 28 PM 3:33

TLX CPCO PARN JKN

ZCZC 1 JACKSON MI NOV 28, 1977

PMS NUCLEAR REGULATORY COMMISSION

/FORMERLY US ATOMIC ENERGY COM/

MR D R HUNTER

799 ROOSEVELT RD

GLEN ELLYN IL 60137

ATT- D R HUNTER

4013
TELEPHONE NBR. 312 858-2660
TELEPHONED TO SC K BY 11/28
DATE ELD 11/28 TIME 400p
ATTEMPTS TO DELIVER.

mail
DEC 1 1977

THIS CONFIRMS EVENT REPORT 77-055 AT PALISADES PLANT, PREVIOUSLY REPORTED BY TELEPHONE TO D R HUNTER ON 11-25-77. AT 0324 ON 11-25-77, LOSS OF OFFSITE POWER OCCURRED, RESULTING IN A LOSS OF MAIN CONDENSER COOLING WATER. THE PLANT WAS IMMEDIATELY TRIPPED MANUALLY. BOTH DIESELS IMMEDIATELY STARTED AND SUPPLIED POWER DURING THE 2.3 HOURS THAT OFFSITE POWER WAS NOT AVAILABLE. OFFSITE POWER AND STARTUP POWER

SF-1201 (PG-00)

WERE SIMULTANEOUSLY LOST, CAUSING T.S. 3.7.1 TO BE VIOLATED. THE PLANT WAS STABILIZED IN THE HOT CONDITION AND WAS BORATED, RESULTING IN A VIOLATION OF T.S. 3.1.1.A. DURING THE EVENT, A 1/2" LEAK DEVELOPED IN THE LETDOWN LINE. LEAKAGE EXCEEDED THE LIMITS OF T.S. 3.1.5. THE LEAK WAS PROMPTLY ISOLATED AND SUBSEQUENTLY REPAIRED.

J G LEWIS/G H PETITJEAN
CONSUMERS POWER COMPANY
PALISADES PLANT

NNNN

DEC 1 1977

SF-1201 (RS-00)