



# Telegram

VEA156(1947)(1-033261C018)PD 01/18/77 1944

1977 JAN 18 PM 6:55

TLX CONSPower JKN

ZCZC 0014 DLY JACKSON MICHIGAN

1-18-77

BOOK NO.

OPR. NO.

PMS NUCLEAR REGULATORY COMMISSION  
(FORMERLY US ATOMIC ENERGY COM)

TELEPHONE NBR.

312-858-2660

TELEPHONED TO

SR

BY 15

ATT: K BAKER

DATE DLD.

1-19

TIME

10:45A

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

ATTEMPTS

mail

THIS IS TO CONFIRM TELECON WITH NED CHOLAS CONCERNING TWO REPORTABLE  
EVENTS AT PALISADES YESTERDAY AFTERNOON.

50-255

FIRST, THE DISCHARGE/LAKE DELTA T WAS EXCEEDED ON A 100 PERCENT PLAN  
TRIP AND AGAIN ON A 35 PERCENT TRIP.

SF-1201 (R5-69)

JAN 24 1977

SECOND, A CONTROL ROD WAS MISALIGNED OVER 8 INCHES WHILE WITHDRAWING  
SD GROUP IN PREPARATION FOR CRITICAL APPROACH. THE LATTER IS DEEMED  
TENTATIVE REPORTABLE PENDING DISCUSSION WITH K R BAKER.

ITEM NOT DISCUSSED WITH NED CHOLAS WAS A SECOND MISALIGNED CONTROL  
ROD JUST PRIOR TO THE 35 PERCENT TRIP. AN OPERATOR REALIZING THE  
PLANT WAS GOING TO TRIP ON LOSS OF FEEDWATER ATTEMPTED TO RUN THE  
RODS IN TO SAVE A REACTOR TRIP AND INADVERTANTLY RAN ONE ROD DOWN  
INSTEAD OF THE WHOLE GROUP.

J G LEWIS

PALISADES PLANT

CONSUMERS POWER COMPANY

SF-1201 (R5-69)

212 W MICHIGAN AVE

ALL HO

NNNN

8306290205 771209  
PDR ADOCK 05000255  
P PDR