

NJK-74-410

Telecopy: Region III, Attention: Mr. C. Feierabend

December 10, 1974

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 2
Docket No. 50-265, DPR-30
Appendix A, Sections 1.O.A.4, 6.6.B.1.a,

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

On December 9, 1974 at 1005 hours, the 2B Reactor Recirc. M. G. set tripped due to valve closure. The recirc. suction valve, however, did not close entirely. The suction valve was started closed by momentarily holding the contactor until the running current decreased to normal, thereby allowing the valve to close normally. Cause of the suction valve failure is under investigation. The 2B recirc. pump will remain off until an outage allows inspection of the suction valve.

This occurrence was discussed by telephone with Mr. C. Feierabend of your office on December 9, 1974. Further information will be provided by Abnormal Occurrence Report AO 50-265/74-27 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

NJK/LFG/vm

cc: Directorate of Licensing
J. S. Abel

8306290271 741219
PDR ADDCK 05000265
S PDR

1255
COPY SENT REGION