

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

February 2, 1973

Mr. John G. Davis, Director
Directorate of Regulatory Operations
U.S. Atomic Energy Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303

Dear Mr. Davis:


This is in further response to your December 4, 1972, letter, RO:II:50-259, 50-260, 50-296, and 50-327, 50-328, on the subject of Limitorque valve operator failures.

Enclosed is a list, by system, of Browns Ferry unit 1 motor-operated valves showing those requiring corrective action to the torque switch torsion spring. We are developing a schedule for completion of corrective action and expect to be able to advise you of that schedule by March 1, 1973.

Valve lists and schedule for completion of corrective actions for Browns Ferry units 2 and 3 and for Sequoyah Nuclear Plant will be provided to you by the following dates:

Browns Ferry unit 2	May 1, 1973
Browns Ferry unit 3	August 1, 1973
Sequoyah units 1 and 2	July 1, 1973

Very truly yours,


J. E. Gilleland
Assistant to the Manager of Power

Enclosure

8307080644 731116
PDR ADOCK 05000259
P PDR

Letter from Tennessee Valley Authority,
J. E. Gilleland, dated February 2, 1973

Enclosure not included due to length of enclosure.

File Log

Ltr to Tennessee Valley Authority

dtd FEB 21 1973

Ltr from Tennessee Valley Authority,

J. E. Gilleland, dtd 2/2/73

cc w/encl:

J. G. Keppler, RO

J. B. Henderson, RO

RO:HQ (4)

Directorate of Licensing (4)

DR Central Files

cc w/encl. w/o attachments

PDR

Local PDR

NSIC

OIS, OR