



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

SERIAL: BSEP-95-0254
10 CFR 50.73

June 2, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325/LICENSE NO. DRP-71
LICENSEE EVENT REPORT 1-95-010

Gentlemen:

In accordance with the Code of Federal Regulations, Title 10, Part 50.73, Carolina Power & Light Company submits the enclosed Licensee Event Report. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is submitted in accordance with the format set forth in NUREG-1022, September 1983.

Please refer any questions regarding this submittal to Mr. M. A. Turkal at (910) 457-3066.

Very truly yours,

J. Cowan, Director-Site Operations
Brunswick Nuclear Plant

JC/jfm

Enclosures

1. Licensee Event Report
2. Summary of Commitments

cc: Mr. S. D. Ebnetter, Regional Administrator, Region II
Mr. D. C. Trimble, NRR Project Manager (Acting) - Brunswick Units 1 and 2
Mr. C. A. Patterson, Brunswick NRC Senior Resident Inspector
The Honorable H. Wells, Chairman - North Carolina Utilities Commission

9506150338 950602
PDR ADOCK 05000325
3 PDR

JE221

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by Carolina Power & Light Company in this document. Any other actions discussed in the submittal represent intended or planned actions by Carolina Power & Light Company. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager-Regulatory Affairs at the Brunswick Nuclear Plant of any questions regarding this document or any associated regulatory commitments.

Commitment	
1.	This event will be included (including simulation) in 4th phase Licensed Operator Regualification to be completed August 18, 1995
2.	Revise applicable Operating Procedures by August 18, 1995, to provide additional information for transferring a Diesel Generator governor from <u>ISOCHRONOUS</u> mode (Auto) to <u>DROOP</u> mode (Control room or Local Manual).