



Commonwealth Edison  
Quad-Cities Generating Station  
Post Office Box 216  
Cordova, Illinois 61242  
Telephone 309/654-2241

NJK-74-303

Telecopy: Region III, Attention: Mr. C. Feierabend

September 30, 1974



J. Keppler, Regional Director  
Directorate of Regulatory Operations  
Region III  
U. S. Atomic Energy Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit One/Two, Docket No.  
50-265, 50-254, DPR-30, 29, Appendix A, Sections 1.0.A.4,  
4.9.A.1.b, 6.6.B.1.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1a within 24 hours of the occurrence.

At 1200 hours on September 29, 1974, with Unit One running at 610 and Unit Two at 306 MWe, 1/2 diesel generator failed to start due to both air valves being closed at the receiver outlet. The diesel generator was started immediately upon the opening of both air valves and a monthly operability test conducted satisfactory. Diesel generators 1 and 2 air system was checked and found to be in proper condition. "S" locks will be provided for all three diesel generator's air receiver outlet valves and shut-off valve to the air start motor.

This occurrence was discussed by telephone with Mr. Feierabend of your office on Sept. 30, 1974. Further information will be provided by Abnormal Occurrence Report AO 50-254/74-31 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY  
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis  
Station Superintendent

NJK/LDR/saa

10000

cc: Directorate of Licensing  
J. S. Abel

8307130195 741009  
PDR ADOCK 05000254  
S PDR

50-265, 254,  
incident

COPY SENT REGION

III