



Commonwealth Edison
Quad-Cities Generating Station
Post Office Box 216
Cordova, Illinois 61242
Telephone 309/854-2241

NJK-74-301

Teletype: Region III, Attention: Mr. G. Feierabend

September 27, 1974

J. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
U. S. Atomic Energy Commission
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station, Unit 1
Docket No. 50-254, DPR-29
Appendix A, Sections 1.0.A.2, 3.8.E, 6.6.B.1.a.

Dear Mr. Keppler:

The purpose of this letter is to provide you with notification of an Abnormal Occurrence as required by Technical Specification 6.6.B.1.a within 24 hours of the occurrence.

At 3:30 p.m. on September 26, 1974, with Unit 1 operating at 806 MWe and Unit 2 at 210 MWe, a radwaste curie inventory revealed a curie content of 3.66 Ci in the tank farm. The content did not go below 2 curies within 24 hours. The waste surge tank had 2.66 curies, because the waste filter was out of service, and water was being sent to the tank for storage. The filter has been returned to service and the surge tank water is being processed.

This occurrence was discussed by telephone with Mr. Feierabend of your office on September 27, 1974. Further information will be provided by Abnormal Occurrence Report AQ 50-254/74-30 which will be submitted within 10 days of the date of this occurrence.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
N. J. Kalivianakis
Station Superintendent

NJK/LEG/er

8307130266 741007
PDR ADOCK 05000254
S PDR

cc: Directorate of Licensing
J. S. Abel

40-
p