

5/17 1200

MV
WU AGCY WHEA

WU MVN ILL
WUA106 HH 1200P CDT
VEB085(1042)(1-008804C138)PD 05/17/76 1039

TLX CONSPower JKN
ZCZC 0001 DLY JACKSON MICHIGAN 5-17-76
PMS US NUCLEAR REGULATORY COM
(FORMERLY US ATOMIC ENERGY COM)
MR J G KEEPLER
799 ROOSEVELT ROAD
GLEN ELLYN, IL 60137
SUBJECT CONFIRMATION OF PROMPT REPORTABLE EVENT
MSIV VALVE INTEGRITY (ER-PAL-76-16)

THIS IS TO CONFIRM MY TELEPHONE REPORT ON MAY 14, 1976 WITH MR E JORDAN, CONCERNING THE PRELIMINARY RESULTS OF AN ANALYSIS OF THE PALISADES MSIVS. WE HAVE CONCLUDED THAT VALVE INTEGRITY MAY BE LOST, IN THE EVENT OF A MAIN STEAM LINE BREAK, FOR THE VALVE ASSOCIATED WITH THE BREAK. A REVIEW OF THE PALISADES FSAR SHOWS THAT THE

STEAM LINE RUPTURE INCIDENT ASSUMED COMPLETE BLOWDOWN OF THE STEAM GENERATOR ASSOCIATED WITH THE STEAM LINE BREAK AND, THEREFORE, THAT THIS TYPE OF INCIDENT HAS BEEN REVIEWED.

D A BIXEL
NUCLEAR LICENSING
CONSUMERS POWER CO
ALL HO
:
WU AGCY WHEA

8308150183 760601
PDR ADOCK 05000255
S PDR

MAY 18 1976