



Telegram

VEB091(0952)(1-007469C132)PD 05/11/1976 09:53 AM 9:53
TLX CONSPower JKN
ZCZC 003 JACKSON MICH 5/11/76
PMS MR K R BAKER
NUCLEAR REGULATORY COMM (FORMERLY AEC)
799 ROOSEVELT RD
GLEN ELLYN, IL 60137

3/2 4LB3 74
858-2660
FDK 134
05-11 1121A
Requested msg just to be mailed.
Mail

PALISADES PLANT - EVENT REPORT PAL -76-014

THIS MESSAGE IS SENT TO CONFIRM OUR CONVERSATION (5/11/76) ABOUT A PROMPT REPORTABLE OCCURRENCE (PAL-ER-014). THE OCCURRENCE INVOLVED REMOVING THE 1-1 DIESEL FROM SERVICE WHILE ONE OF THE HIGH-PRESSURE SAFETY INJECTION PUMPS ON THE OPPOSITE BUS WAS INOPERABLE. THIS IS

SF-1201 (RS-69)

CONSIDERED REPORTABLE SINCE THE UNIT WAS IN OPERATION WHEN AN OPERATION SUBJECT TO A LIMITING CONDITION WAS LESS CONSERVATIVE THAN THE LEAST CONSERVATIVE ASPECT OF THE LIMITING CONDITION FOR OPERATION ESTABLISHED IN THE TECHNICAL SPECIFICATIONS.

J G LEWIS/G B SLADE
PALISADES PLANT
CONSUMERS POWER COMPANY
CBW
NNNN

8308150186 760511
PDR ADDCK 05000255
S PDR

SF-1201 (RS-69)