



Telegram

VEC214(1733)(1-029921C114)PD 04/23/76 1730

TLX CONSPower JKN

ZCZC 002 DLY JACKSON MICHIGAN 4-23-76

PMS US NUCLEAR REGULATORY COM

(FORMERLY US ATOMIC ENERGY COM)

ATT: J G KEPPLER

799 ROOSEVELT RD

GLEN ELLYN, IL 60137

AC 312 BOOK NO. OPR. NO.
TELEPHONE NO. 858-2660
TELEPHONED TO 04-23 BY 117
DATE DEL. 04-23 TIME 4:52p
ATTEMPTS TO DELIVER: Mail

SUBJECT: EVENT REPORT PAL 76-011

ABNORMAL DEGRADATION OF PRIMARY CONTAINMENT DUE TO EXCEEDING LOCAL
LEAK TESTING ALLOWABLE LIMITS.

DURING ITS LEAK TESTING THE PENETRATION NUMBER 46 CONTAINMENT
VENT HEADER - WAS FOUND TO EXCEED ITS ALLOWABLE LIMITS.

SF-1201 (R5-69)

APR 27 1976

WE FIND THIS IS REPORTABLE UNDER PALISADES TECHNICAL SPECIFICATIONS
6.9.2.A "3" - REPORTABLE OCCURRENCES.

CC: R B DE WITT, PARNALL
R B SEWELL, PARNALL

J G LEWIS/K W BERRY
CONSUMERS POWER COMPANY
PALISADES NUCLEAR PLANT
ALL HO

C

8308150363 760506
PDR ADOCK 05000255
S PDR

SF-1201 (R5-69)