



Consumers
Power
Company

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

March 10, 1976

Mr James G. Keppler
Office of Inspection Enforcement
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137



DOCKET 50-255, LICENSE DPR-20
PALISADES PLANT, ER-76-04
MSIV CLOSING PRESSURE INSTRUMENTATION

Attached is a reportable occurrence which relates to the Palisades Plant. This occurrence has been classified as a reactor protection system or engineered safety feature instrument setting which was found to be less conservative than those established by the Technical Specifications but which do not prevent the fulfillment of the functional requirements of the affected system.

David A. Bixel
Assistant Nuclear Licensing Administrator

8308150427 760310
PDR ADOCK 05000255
S PDR

2626

MAR 11 1976

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME						LICENSE NUMBER							LICENSE TYPE					EVENT TYPE					
01	M	I	P	A	L	1	0	0	-	0	0	0	0	-	0	0	4	1	1	1	1	0	3
7	8	9			14	15									25	26				30	31	32	

REPORT TYPE		REPORT SOURCE		DOCKET NUMBER							EVENT DATE					REPORT DATE									
01	CON'T			L	L	0	5	0	-	0	2	5	5	0	2	2	1	7	6	0	3	1	0	7	6
7	8	57	58	59	60	81							88	69				74	75					80	

[illegible]

02	During testing, the MSIV closure set point was found to be below the Technical	80
03	Specifications limit of "greater than 500 psia" on two instruments. PIC 0751D was	80
04	found set at 495 psia and PIC 0752A was found at 499 psia."	80
05	(ER-76-04)	80
06		80
	PRIME	80

SYSTEM CODE		CAUSE CODE	COMPONENT CODE					COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION			
0	7	C	D	B	I	N	S	T	R	U	N	I	1	3	0	Y
7	8	9	10	11	12					17	43	44			47	48

CAUSE DESCRIPTION

08	Instrument set point drift. Set point was adjusted. International Instrument	80
09	Model No 9223-E	80
10		80

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	H	000		NI		b		NA	
7	8	9	10	11	12	13	44	45	80
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE	
12	Z	Z		NA				NA	
7	8	9	10	11	44	45			80

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION
13	0	0	0	Z	NA

PERSONNEL INJURIES

NUMBER				DESCRIPTION
1	4	0	0	NA

PROBABLE CONSEQUENCES

15 Since other set points were satisfactory, proper initiation would have occurred.

LOSS OR DAMAGE TO FACILITY

TYPE			DESCRIPTION
1	6	2	NA

PUBLICITY

17	NA	80
----	----	----

ADDITIONAL FACTORS

18	NA	80
----	----	----

7 8 9 19 | 80