

2/10 1:30pm

Rec'd
1:35pm

WD MVN ILL

WU AGCY WHEA

WUA 141 JP 113P CST

VED141(1345)(1-018099C041)PD 02/10/76 1342

TLX CONSPower JKN

ZCZC 003 DLY JACKSON MICH 2/10/76

PMS MR K R BAKER

NUCLEAR REGULATORY COMMISSION (FORMERLY AEC)

799 ROOSEVELT RD

GLEN ELLYN, IL

SUBJECT PALISADES PLANT

PRELIMINARY EDDY CURRENT INSPECTION RESULTS

ER-76-003

THIS IS TO CONFIRM YESTERDAY S TELECON BETWEEN R B DE WITT AND
K R BAKER CONCERNING PRELIMINARY RESULTS OF THE PALISADES STEAM
GENERATOR INSPECTION. THESE RESULTS INDICATE THAT SOME STEAM

GENERATOR TUBES HAVE DEGRADED MORE THAN EXPECTED.

50-255

D A BIXEL

PALISADES PLANT

CONSUMERS POWER COMPANY

CBW

WU MVN ILL

:

WU AGCY WHEA

8308150435 760224
PDR ADOCK 05000255
S PDR

UNCL 4 0 1010
FEB 10 1976