

LICENSEE EVENT REPORT

Palisades

(PLEASE PRINT ALL REQUIRED INFORMATION)

(1) CONTROL BLOCK: 1 0

(2) LICENSEE NAME

(3) LICENSE NUMBER

(4) LICENSE TYPE

(5) EVENT TYPE

J 1 M I P A L 1 0 0 - 0 0 0 0 0 - 0 0 4 1 1 1 1 9 9
7 8 8 14 15 25 26 30 31 32
(6) CATEGORY (7) REPORT TYPE (8) REPORT SOURCE (9) DOCKET NUMBER (10) EVENT DATE (11) REPORT DATE
0 1 CONT * * T L 0 5 0 - 0 2 5 5 1 2 2 1 7 5 0 1 0 5 7 6
7 8 57 58 59 60 61 68 69 74 75 80

EVENT DESCRIPTION

0 2 When the 'A' cooling tower pump was removed from service following plant shutdown, the
7 8 9 80
0 3 water lost to the mixing basin caused the temperature at discharge to be 45.5 degrees
7 8 9 80
0 4 F. The delta-T was 8.4 degrees F which is above the Tech Spec limit of 5 degrees F.
7 8 9 80
0 5 Due to the infrequency of occurrence and the negligible impact on environment, a Tech
7 8 9 80
0 6 Spec Change has been requested to permit short periods of time (continued on Line 18)
7 8 9 80

(13) SYSTEM CODE (14) CAUSE CODE (15) COMPONENT CODE (16) PRIME COMPONENT SUPPLIER (17) COMPONENT MANUFACTURER (18) VIOLATION
0 7 H F B V A L V O P A B 2 5 0 Y
7 8 9 10 11 12 17 43 44 47 48

CAUSE DESCRIPTION (19)

0 8 The valve closing time is too slow to prevent weir overflow following pump trip.
7 8 9 80
0 9
7 8 9 80

(20) FACILITY STATUS (21) % POWER (22) OTHER STATUS (23) METHOD OF DISCOVERY (24) DISCOVERY DESCRIPTION (25) FORM OF ACTIVITY RELEASED (26) CONTENT OF RELEASE (27) AMOUNT OF ACTIVITY (28) LOCATION OF RELEASE
1 1 G 0 0 0 NA B Environmental Monitoring Program
7 8 9 10 12 13 44 45 46 80
1 2 Z Z NA
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES

(29) NUMBER (30) TYPE (31) DESCRIPTION
1 3 0 0 0 Z NA
7 8 9 11 12 13 80

PERSONNEL INJURIES

(32) NUMBER (33) DESCRIPTION
1 4 0 0 0 NA
7 8 9 11 12 80

Probable Consequences (34)

1 5 No effect on public health and safety.
7 8 9 80

LOSS OR DAMAGE TO FACILITY

(35) TYPE (36) DESCRIPTION
1 5 Z NA
7 8 9 10 80

PUBLICITY (37)

1 7 Copies of this report are being sent to MI news media.
7 8 9 80

ADDITIONAL FACTORS (38)

1 d with delta-T above 5 degrees F. (AO-75-27)
7 8 9 80

8308160571 760105
PDR ADOCK 05000255
S PDR



Consumers
Power
Company

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

January 5, 1976



Mr. J. G. Keppler
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

1E FILE COPY

DOCKET 50-255, LICENSE DPR-20
PALISADES PLANT

Transmitted attached is a "License Event Report" for the Palisades Plant.

Ralph B. Sewell
Nuclear Licensing Administrator

CC: Director of Nuclear
Reactor Regulation,
USNRC

217

JAN 1976

COPY SENT REGION

III