



Telegram

WU 117 (1223) (1-0152710000) PD 10/15/75 1220

OCT 18 PM 12:25

TEX CONSUMER JAN

2020 DUB DLY JACKSON MICHIGAN 10/15/75

FMS US NUCLEAR REGULATORY COMMISSION

(FORMERLY AEC)

MR. K. H. BAKER

REGION III

730 ROOSEVELT ROAD

ELLEN ELLEN, IL 60137

SUBJECT - PALISADES PLANT -

ABNORMAL OCCURRENCE REPORT

THIS TMA CONFIRMS MY TELEPHONE CONVERSATION WITH K. H. BAKER
ON OCTOBER 15, 1975 IN WHICH I REPORTED AN ABNORMAL OCCURRENCE
AT PALISADES. THE DISCHARGE TEMPERATURE OF WATER FROM THE
MIXING BASIN WAS IN EXCESS OF THE 3 DEGREES ALLOWED BY TECH

SF-1201 (RS-69)

OCT 17 1975

SPECS FOR A PERIOD OF ABOUT 1.5 HOURS WHILE A DIVER WAS INSTALL-
ING TEMPERATURE MONITORING EQUIPMENT.

CC: R. B. DEWITT

R. B. DEWELL

J. E. BLADE

CONSUMERS POWER COMPANY

213 W. MICHIGAN AVENUE

ALL DBV

NNNN

8308160593 751015
PDR ADOCK 05000255
S PDR

Files

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date : Palisades Plant October 20, 1975

Distribution:
IE Chief, FC&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FC&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files

