



Telegram

VEB168(1413)(1-021747A258)PD 09/15/75 1409
TLX CONSPOWER JKN
ZCZC 005 JACKSON MICH 9/15/75
PMS MR K R BAKER
NRC (FORMERLY ATOMIC ENERGY COMMISSION)
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, IL 60137

312 BOOK NO. 858-2660
TELEPHONE NO. 858-2660
TELEPHONED TO 858-2660
DATE DLD. 09-15 TIME 337P
ATTEMPTS TO DELIVER 1

SUBJECT: PALISADES PLANT - ABNORMAL OCCURRENCES

THIS IS TO INFORM YOU OF TWO ABNORMAL OCCURRENCES WHICH TOOK PLACE AT THE PALISADES PLANT OVER THE LAST WEEKEND. THE FIRST INVOLVED A REDUCED CONCENTRATION OF BORIC ACID IN THE SAFETY INJECTION TANKS. THE CONCENTRATIONS WERE ABOUT 20 PPM BELOW

SEP 17 10.3

THOSE REQUIRED BY TECH SPECS.

THE SECOND OCCURRENCE INVOLVED THE FAILURE OF HIGH-PRESSURE SAFETY INJECTION VALVE MOV-3007. FLOW COULD NOT BE DEMONSTRATED THROUGH THE VALVE; THEREFORE, WE HAVE ALIGNMENT SUCH THAT THE REDUNDANT HIGH-PRESSURE SAFETY INJECTION SYSTEM IS BEING UTILIZED AS A REPLACEMENT FOR THE NORMAL PATH. WE FEEL THAT THIS MEETS REQUIREMENTS OF TECH SPECS. FURTHER INFORMATION ON BOTH OF THESE OCCURRENCES WILL BE TRANSMITTED WITHIN THE REQUIRED 10 DAYS.

G B SLADE
PALISADES PLANT
CONSUMERS POWER COMPANY

8308160624 750918
PDR ADOCK 05000255
S PDR

CBW