



Telegram

T816P EST JUL 4 75 AA048

DUPLICATE OF TELEPHONED TELEGRAM FY ASK 526 4503

AAB193(1819)(2-018244E185)PD 07/04/75 1819

ICS IPMMTZZ CSP

8038784984 TDMT PICKENS SC 75 07-04 0619P EST

PMS NORMAN MOSELY, DLH

NRC REGION 2 230 PEACHTREE ST NORTHWEST

ATLANTA GA 30303

AT APPROXIMATELY 0635 7/3/75 KEOWEE UNIT TWO BECAME INOPERABLE
BECAUSE OF GOVERNOR PROBLEMS THE UNIT IS OPERABLE MANUALLY BUT AUTO
START UP CAN NOT BE DONE. A LEE GAS TURBINE COULD NOT BE TIED IN
THROUGH A ISOLATED LINE TO SUPPLY AND BUY POWER SHUT DOWN WAS
INITIATE ON OPERATING OCONEE UNIT AT APPROXIMATELY 1845 7/4/75.
COMPLETION OF REPAIRS TO KEOWEE UNIT IS EXPECTED PRIOR TO 2400
7/4/75. INVESTIGATION INTO LEE UNIT FAILURE CONTINING

J ED SMITH OCONEE NUCLEAR STATION SENECA SC 29678

NNNN

*July 7 1975
2330 mark*

7-1201 (R5-69)

8308170159 750722
PDR ADOCK 05000259
S PDR