



Telegram

1110A EST JUL 9 75 AC055

AAE066(1005)(2-010090E190)PD 07/09/75 1005

ICS IPMRNCZ CSP

2057298316 TDRN ATHENS AL 45 07-09 1005A EST

PMS US NUCLEAR REGULATORY COMMISSION, DLR

230 PEACHTREE ST NORTHWEST SUITE 818

ATLANTA GA 30303

BFA0 50-260/759T DURING REFERBISHING OF UNIT 2 MAIN STEAM RELEASE  
VALVE 1 VALVE WAS FOUND TO HAVE A BROKEN STEM ON THE SECOND STAGE  
PILOT. THE BREAK POINT WAS JUST UNDER THE LOCK NUT ABOVE THE  
ACTUATING PISTON. NRC ON SITE INSPECTOR ADVISED

H J GREEN BROWNS FERRY NUCLEAR PLANT

NNNN

F-1201 (R5-69)

8308170169 750722  
PDR ADDCK 05000259  
S PDR

*file*

Telegram to N. C. Moseley from Tennessee Valley Authority dated July 4, 1975.

DISTRIBUTION:

50-260/75-9T

H. D. Thornburg, IE

IE:HQS (4)

Office of Standards Development

Central Files

Division of Reactor Licensing (4)

PDR

Local PDR

NSIC

TIC

STATE

*50-260  
inquiry*