



CRAM
Telegram

TBB432(1442)(2-029119E148)PD 05/28/75 1441

ICS IPMBNGZ CSP

2057298316 TDBN ATHENS AL 55 05-23 0241P EST

FON 4045266068

US NUCLEAR REGULATORY COMMISSION

230 PEACHTREE ST NW SUITE 818

ATLANTA GA 30303

BFAO-50-259/759T AT APPROXIMATELY 1530 ON 5-27-75 UNIT 1 A AND B
SRM'S WERE MADE UNAVAILABLE DUE TO INADVERTENT DISCONNECTION OF THE
SIGNAL CABLE THIS REDUCED THE OPERABLE SRM'S TO 1 SINCE D WAS
ALREADY OUT OF SERVICE THE REACTOR WAS IN COLD SHUTDOWN THE CABLES
WERE RECONNECTED AND THE FUNCTION RESTORED

H J GREEN BROWN FERRY NUCLEAR PLANT

NNNN

01 (R5-69)

8308180176 750528
PDR ADOCK 05000259
S PDR