

MGMATLT HSB  
2-008949E142 05/22/75

ICS IPMBNGZ CSP

2057298316 MGM TDRN DECATUR AL 100 05-22 0904A EST  
ZIP



western union

Mailgram



US NUCLEAR REGULATORY COMMISSION, DUPLICATE  
230 PEACHTREE ST NORTHWEST SUITE 818  
ATLANTA GA 30303

BFA0-50-259/758T DURING ROUTINE SURVEILLANCE TEST ON MAY 21 1975 AT  
ABOUT 0945 HOURS "A" DIESEL GENERATOR FAILED TO START STARTING AIR  
MOTORS HAVE BEEN CHANGED OUT AND SUCCESSFUL TESTING ACCOMPLISHED UNITS  
1 AND 2 WERE IN COLD SHUTDOWN  
H J GREEN BROWNS FERRY NUCLEAR PLANT

09:04 EST

MGMATLT HSB

8308180189 750530  
PDR ADOCK 05000259  
S PDR