

MGHATLT HSB

2-036087E038 02/07/75

ICS IPMBNGZ CSP

2057298316 MGM TDBN ATHENS AL 100 02-07 0556P EST

ZIP



western union

Mailgram



U.S. NUCLEAR REGULATORY COMMISSION
230 PEACHTREE ST NORTHWEST SUITE 818
ATLANTA GA 30303

BFAO-50-259/752TDOING A FUNCTIONAL TEST OF THE CORE SPRAY PIPING LOOP 2
ON 2-5-75 A SMALL LEAK WAS DISCOVERED IN A 3/4 INCH CARBON STEEL TEST
CONNECTION OUTSIDE THE CONTAINMENT BOUNDARY. THE UNIT WAS IN THE COLD
SHUT DOWN CONDITION.

H J GREEN BROWNS FERRY NUCLEAR PLANT

17:56 EDT

MGHATLT HSB

8308180240 750207
PDR ADDCK 05000259
S PDR

COPIES SENT TO: PDR ☒
LPDR ☐
NSIC ☐
TIC ☐