

COPY



**Consumers
Power
Company**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

April 17, 1975

Division of Reactor Licensing
US Nuclear Regulatory Commission
Washington, DC 20555

Re: Docket 50-255
License DPR-20
Palisades Plant
AO-75-8

Gentlemen:

On April 7, 1975 you were notified of an occurrence involving Palisades Plant cooling water discharge temperatures which were thought to be higher than the allowable limit. The occurrence was designated AO-75-8.

A review of our temperature measuring technique has disclosed the temperature measurements to be in error. The revised measurements show the discharge temperatures to be within the allowable discharge limit.

AO-75-8, therefore, has been canceled.

Yours very truly,

Ralph B. Sewell (Signed)

DAB/mel

Ralph B. Sewell
Nuclear Licensing Administrator

CC: JGKeppler, USNRC

8308220056 750417
PDR ADOCK 05000255
S PDR

(2)

COPY SENT REGION II

4388