

# WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard  
Vice President Plant Operations

June 14, 1995

WO 95-0100


U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D. C. 20555

Subject: Rocket No. 50-482: May, 1995, Monthly  
Operating Report

Gentlemen:

Attached is the May, 1995, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a  
D. F. Kirsch (NRC), w/a  
J. F. Ringwald (NRC), w/a  
J. C. Stone (NRC), w/a

9506190292 950531  
PDR ADCK 05000482  
R PDR

IF24  
11

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: May YEAR: 1995

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 123

## SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of May, 1995. This report is being provided pursuant to Technical Specification 6.9.1.8.

### I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power in Mode 1 for the month of May, 1995.

### II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

NONE

OPERATING DATA REPORT  
DOCKET NO. 50-482  
WOLF CREEK GENERATING STATION  
WOLF CREEK NUCLEAR OPERATING CORPORATION  
DATE 6-7-95  
TELEPHONE 316-364-8831

## OPERATING STATUS

1. Reporting Period: May, 1995 Gross Hours in Reporting Period: 744
  2. Currently Authorized Power Level (MWt): 3565 Max Depend. Capacity (MWe-Net): 1160  
Design Electrical Rating (MWe-Net): 1170
  3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
  4. Reasons for Restriction (If Any): N/A
- |   | This Month       | Yr. to Date       | Cumulative         |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical     | <u>744</u>       | <u>3511.7</u>     | <u>69,479.8</u>    |
| 6. Reactor Reserve Shutdown Hours           | <u>0.0</u>       | <u>0.0</u>        | <u>339.8</u>       |
| 7. Hours Generator on Line                  | <u>744</u>       | <u>3,488.1</u>    | <u>68,642.7</u>    |
| 8. Unit Reserve Shutdown Hours              | <u>0.0</u>       | <u>0.0</u>        | <u>0.0</u>         |
| 9. Gross Thermal Energy Generated (MWh)     | <u>2,634,001</u> | <u>12,222,003</u> | <u>227,254,321</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>915,449</u>   | <u>4,244,022</u>  | <u>79,008,237</u>  |
| 11. Net Electrical Energy Generated (MWh)   | <u>877,330</u>   | <u>4,067,773</u>  | <u>75,442,447</u>  |
| 12. Reactor Service Factor                  | <u>100.0%</u>    | <u>96.9%</u>      | <u>81.4%</u>       |
| 13. Reactor Availability Factor             | <u>100.0%</u>    | <u>96.9%</u>      | <u>81.8%</u>       |
| 14. Unit Service Factor                     | <u>100.0%</u>    | <u>96.3%</u>      | <u>80.4%</u>       |
| 15. Unit Availability Factor                | <u>100.0%</u>    | <u>96.3%</u>      | <u>80.4%</u>       |
| 16. Unit Capacity Factor (Using MDC)        | <u>101.7%</u>    | <u>96.8%</u>      | <u>77.9%</u>       |
| 17. Unit Capacity Factor (Using Design MWe) | <u>100.8%</u>    | <u>96.0%</u>      | <u>75.5%</u>       |
| 18. Unit Forced Outage Rate                 | <u>0.0%</u>      | <u>3.7%</u>       | <u>5.1%</u>        |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):  
No outages are scheduled at this time.
  20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL  
DOCKET NO. 50-482  
WOLF CREEK GENERATING STATION  
WOLF CREEK NUCLEAR OPERATING CORPORATION  
DATE 6-7-95  
TELEPHONE 316-364-8831

MONTH May, 1995

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1	<u>1183</u>
2	<u>1183</u>
3	<u>1184</u>
4	<u>1177</u>
5	<u>1183</u>
6	<u>1183</u>
7	<u>1183</u>
8	<u>1183</u>
9	<u>1183</u>
10	<u>1183</u>
11	<u>1169</u>
12	<u>1181</u>
13	<u>1181</u>
14	<u>1180</u>
15	<u>1180</u>
16	<u>1178</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17	<u>1178</u>
18	<u>1172</u>
19	<u>1172</u>
20	<u>1179</u>
21	<u>1178</u>
22	<u>1178</u>
23	<u>1178</u>
24	<u>1179</u>
25	<u>1175</u>
26	<u>1178</u>
27	<u>1178</u>
28	<u>1179</u>
29	<u>1179</u>
30	<u>1178</u>
31	<u>1178</u>

## UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 6-7-95TELEPHONE 316-364-8831

No	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
NA	NA	NA	NA	NA	NA	NA

SUMMARY: The unit operated at or near 100% in Mode 1 for the month of May, 1995.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL  
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM  
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM  
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED  
 5. REDUCED LOAD  
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH May, 1995

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
NA	NA	NA