

western union

Telegram

VEC241(1722)(1-036227C291)PD 10/18/74 1718

1974 OCT 18 PM 4:32

TLX CONSPower JKN

ZCZC 003 DLY JACKSON MICH

10-18-74

PMS ATOMIC ENERGY COMMISSION - ATT: REGION III

799 ROOSEVELT RD

GLEN ELLYN, ILLINOIS 60137

RON COOK

TELEPHONE WBR.

TELEPHONED TO

DATE DLD 10/19/74 TIME 8:51A

ATTEMPTS TO DELIVER.

312-858-2660

WWD BY MK


Mail

THIS IS TO DOCUMENT AN INCIDENT WHICH OCCURRED AT PALISADES YESTERDAY AT 2100 HOURS. INSPECTOR R J COOK WAS INFORMED AT THE PLANT TODAY.

8308220450 741115
PDR ADOCK 05000255
S PDR

UPON INITIATION OF THE RIGHT SIDE SIS TEST CIRCUIT, STARTUP POWER TO THE PLANT WAS LOST BY SPURIOUS OPERATION OF A TRANS-FORMER PROTECTION RELAY. EMERGENCY DIESELS STARTED AND

SF-1201 (RS-69)



western union

Telegram

AUTOMATICALLY CLOSED TO 2400 VOLT BUSES AND PLANT RECOVERY WAS WITHOUT INCIDENT. THE PLANT WAS SUBCRITICAL WITH SHUTDOWN RODS WITHDRAWN AND AT 530 DEGREES FAHRENHEIT.

THE TRANSFORMER RELAYS ARE BACK-UP PROTECTION AND WILL BE LEFT OUT OF SERVICE PENDING RESOLUTION OF THE PROBLEM.

WE ARE CONSIDERING THIS AN UNUSUAL INCIDENT AND A REPORT WILL FOLLOW WITHIN 30 DAYS.

J G LEWIS

OPERATIONS SUPT, PALISADES PLANT
CONSUMERS POWER COMPANY

CBW

SF-1201 (RS-69)