

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342-3840



Harry P. Salmon, Jr.
Resident Manager

June 13, 1995
JAFP-95-0281

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555


Attention: Document Control Desk
SUBJECT: OPERATING STATUS REPORT
Reference: DOCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant
Operating Status Report for the month of **May 1995**.

If there are any questions concerning this report, please contact
Russ Flagg, Performance Engineering, at (315) 349-6768.

Very truly yours,


HARRY P. SALMON, JR.

HPS:RGF:rfh *rfh*
Enclosure

CC: F. Edler *fcc*
JAF Department Heads
White Plains Office
TS File
RMS, JAF

9506190304 950531
PDR ADOCK 05000333
R PDR

TE24
11

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JUNE 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (515) 349-6768

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 950501 - 950531
3. Licensed Thermal Power (MWT): 2436
4. Nameplate Rating (Gross MWE): 883.0
5. Design Electrical Rating (Net MWE): 816.0
6. Maximum Dependable Capacity (Gross MWE) 801.0
7. Maximum Dependable Capacity (Net MWE) 773.6

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons:

9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	<u>708.5</u>	<u>3623.0</u>	<u>173952.0</u>
12. Number of Hours Reactor was Critical:	<u>708.5</u>	<u>1671.6</u>	<u>120952.4</u>
13. Reactor Reserve Shutdown Hours:	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line:	<u>708.5</u>	<u>1560.0</u>	<u>116820.6</u>
15. Unit Reserve Shutdown Hours:	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH):	<u>1734888.0</u>	<u>3542710.0</u>	<u>257751377.0</u>
17. Gross Electrical Energy Generated (MWH):	<u>580810.0</u>	<u>1180390.0</u>	<u>87573200.0</u>
18. Net Electrical Energy Generated (MWH):	<u>562170.0</u>	<u>1140890.0</u>	<u>84128765.0</u>
19. Unit Service Factor:	<u>95.2</u>	<u>43.1</u>	<u>67.2</u>
20. Unit Availability Factor:	<u>95.2</u>	<u>43.1</u>	<u>67.2</u>
21. Unit Capacity Factor (using MDC Net):	<u>97.6</u>	<u>40.7</u>	<u>69.3</u>
22. Unit Capacity Factor (using DER Net):	<u>92.6</u>	<u>38.6</u>	<u>59.3</u>
23. Unit Forced Outage Rate:	<u>4.7</u>	<u>2.2</u>	<u>11.6</u>

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):

25. If shutdown at end of report period, estimated date of startup: 06/07/95

26. Units in Test Status (prior to commercial operation):
- | | FORECAST | ACHIEVED |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: MAY 1995

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JUNE 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315) 386-6768

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	800	17	798
2	800	18	798
3	799	19	797
4	794	20	798
5	799	21	796
6	798	22	797
7	799	23	796
8	798	24	797
9	798	25	798
10	798	26	794
11	797	27	797
12	797	28	795
13	797	29	798
14	799	30	296
15	798	31	0
16	798		

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT

REPORT MONTH: MAY95

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: JUNE 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

NO.	DATE	TYPE	D U H R O A U T R I S T R I C T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M C P O D N E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	5/30/95	F	35.5	D	2	95.010	AD	ISV	A 1/4" manual valve (jet pump to recirc pump suction) packing leak exceeded Tech Spec limits. The packing was replaced with a different style that is less prone to gross failure.

1

F: FORCED
S: SCHEDULED

2

REASON:
A. EQUIPMENT FAILURE (EXPLAIN)
B. MAINTENANCE OR TEST
C. REFUELING
D. REGULATORY RESTRICTION
E. OPERATOR TRAINING AND LICENSE EXAMINATION
F. ADMINISTRATIVE
G. OPERATIONAL ERROR (EXPLAIN)
H. OTHER (EXPLAIN)

3

METHOD:
1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUED
5. REDUCED LOAD
9. OTHER

4

EXHIBIT G -INSTRUCTIONS
FOR PREPARATION OF DATA ENTRY
SHEETS FOR LICENSEE EVENT
REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: MAY 1995

DOCKET NO.:	50-333
UNIT NAME:	FITZPATRICK
DATE:	JUNE 1995
COMPLETED BY:	RUSSELL FLAGG
TELEPHONE:	(315)349-6768

The FitzPatrick Plant remained in operation until unidentified primary containment leakage forced a shutdown on 05/30/95 at 1229 hours (generator off-line).