



Telegram

1974 SEP -9 AM 10: 42

VEB120(1136)(1-010034C252)PD 09/09/74 1132

TLX CONSPower JKN

ZCZC 001 9-9-74 JACKSON MICH

PHS US AEC - ATT: RON COOK -

199 ROOSEVELT RD

JEAN ELLYN, IL

TELEPHONE NBR. 312-858-2660
TELEPHONED TO CB BY 22
DATE DLD 9/9 TIME 1241P
ATTEMPTS TO DELIVER mail

REPORT NUMBER 74-19

OCCURRENCE DATE 9-6-74

REPORT DATE 9-7-74

SUBJECT - FAILURE OF RIA-0707 STEAM GENERATOR BLOWDOWN - LIQUID -
MONITOR TO TRIP ON HIGH RADIATION.

DESCRIPTION OF OCCURRENCE-

ON 9-6-74 AT 1500 IT WAS FOUND THAT RIA-0707 STEAM GENERATOR BLOW-
DOWN - LIQUID - MONITOR HAD NOT TRIPPED ON HIGH RADIATION.

THE HIGH RADIATION TRIP CLOSES THE FOLLOWING ISOLATION VALVES ON
CV-0704, 0738, 0739, 0770 AND 0771.

THE ABOVE-MENTIONED VALVES WERE PLACED IN THE MANUALLY CLOSED
POSITION. THE RIA WAS REMOVED FROM SERVICE, REPAIRED AND RE-
INSTALLED.

THE QUARTERLY TRIP TESTS OF ALL PROCESS MONITORS WERE REVIEWED WITH
NO ABNORMALITIES OF THIS KIND BEING NOTED. A QUARTERLY TEST OF THE
ALARMS AND TRIP FUNCTIONS IS SCHEDULED FOR THE WEEK OF SEPTEMBER 16.

SF-1201 (RS-66)

FURTHER INVESTIGATION IS UNDERWAY TO DETERMINE THE CAUSE OF THE
FAILURE.

THIS TELEX IS A FOLLOW-UP OF THE CONVERSATION WITH MR. R. COOK AT
1600 ON 9-6-74 AT PALISADES.

R B DE WITT

CONSUMERS POWER COMPANY

8308230051 740916
PDR ADOCK 05000255
S PDR