



Telegram

VED254(1555)(1-030456A200)PD 07/19/74 1551

TLX CONSPower JKN

ZCZC 005 JACKSON MICHIGAN 7-19-74

PMS US ATOMIC ENERGY COMMISSION

ATT: E JORDAN

DIRECTORATE OF REGULATORY OPERATIONS

REGION III

799 ROOSEVELT ROAD

GLEN ELLYN, IL 60137

RE: DOCKET 50-255

DPR-20

TELEGRAMS (OTHER THAN MONEY ORDERS)  
IN PHYSICAL DELIVERY FOR DELIVERY  
12:05P 312-858-2660  
mail  
Call Mon

CONFIRMING OUR TELEPHONE CONVERSATION OF JULY 18, 1974, GB  
SZCZOTKA, R E MC CALEB AND MYSELF DESCRIBED DEFICIENCIES IN THE  
IMPLEMENTATION OF PROCEDURES ASSOCIATED WITH THE TUBE PLUGGING  
IN THE PALISADES STEAM GENERATORS. AFTER DISCUSSING THE MATTER,

SF-1201 (RS-69)

IT WAS CONCLUDED THAT THESE WERE CONSIDERED AN ABNORMAL OCCUR-  
RENCE IN ACCORDANCE WITH PARAGRAPH 1.4.F OF THE TECHNICAL SPECIFI-  
CATIONS. A WRITTEN REPORT WILL BE SUBMITTED AS REQUIRED BY THE  
TECHNICAL SPECIFICATIONS.

R B SEWELL

NUCLEAR LICENSING ADMINISTRATOR

PARNALL ROAD

CONSUMERS POWER COMPANY

COPY SENT TO: PDR ✓  
LPDR ✓  
NSIC  
TIC

8308230103 740909  
PDR ADDCK 05000255  
S PDR

ALL RO

CC- R B DE WITT, PALISADES

R L HAUETER, PARNALL ROAD

JUL 24 1974

SF-1201 (RS-69)